

REFER DRAWING S00 FOR GENERAL NOTES

WALL PANEL NOTES:

1. WALL PANELS TO BE 100 THICK UNO. (25mm MAX. GROOVE DEPTH) SL82 CENTRAL + N16 EDGE BARS CENTRAL (UNO) & ADDITIONAL REINFORCEMENT AS NOTED.
2. WALL PANELS TO BE 150 THICK UNO. (25mm MAX. GROOVE DEPTH) SL102 CENTRAL + N20 EDGE BARS CENTRAL (UNO) & ADDITIONAL REINFORCEMENT AS NOTED.
3. WALL PANELS TO BE 175 THICK UNO. (25mm MAX. GROOVE DEPTH) SL92 EACH FACE (UNO) + N16 EDGE BARS EACH FACE (UNO) & ADDITIONAL REINFORCEMENT AS NOTED.
4. WALL PANELS TO BE 200 THICK UNO. (25mm MAX. GROOVE DEPTH) SL102 EACH FACE (UNO) + N16 EDGE BARS EACH FACE (UNO) & ADDITIONAL REINFORCEMENT AS NOTED.
5. LIFT/STAIR CORE WALL PANELS TO BE 200 THICK UNO. (25mm MAX. GROOVE DEPTH) SL81 EACH FACE + N16 EDGE BARS EACH FACE (UNO) & ADDITIONAL REINFORCEMENT AS NOTED.
6. REFER TO WALL PANEL ELEVATIONS & DETAILS FOR DOWEL FIXINGS.
7. CONFIRM PANEL SIZES WITH PRECAST CONTRACTOR, THE ENGINEER IS TO BE NOTIFIED IF PANEL SIZES ARE TO BE ADJUSTED.
8. REINFORCEMENT SPECIFIED IS FOR "IN POSITION" LOADING ONLY. THE MANUFACT' IS TO PROVIDE ANY 'ADDITIONAL REQ' IF REQUIRED FOR CASTING, TRANSPORTATION, LIFTING, ERECTION ETC.
9. REFER TO ARCHITECTURAL DRAWINGS FOR ANY ARCH' FEATURES, PENETRATIONS, DP'S ETC.
10. REFER TO SECTIONS & ELEVATIONS FOR ADDITIONAL REINFORCEMENT.
11. ENSURE APPROPRIATE COVER TO CAST IN PLATE LUGS AT GROOVE LOCATIONS THE ENGINEER IS TO BE NOTIFIED IF SUCH CLASHING OCCURS.
12. PENETRATIONS IN WALL PANELS FOR SERVICES ARE TO BE CONSTRUCTED DURING CASTING OF WALL PANELS.
13. ALL FERRULES TO BE RAMSET ROUND FERRULES x 96mm LONG WITH N12 x 300 LONG BACKING ROD UNO.
14. PROVIDE MINIMUM CLEAR COVER OF 35mm TO ALL REINFORCEMENT.
15. PROVIDE 'XYPEX' OR SIMILAR APPROVED MOISTURE PROOFING ADDITIVE TO ALL WALL PANELS RETAINING SOIL, TO MANUFACTURERS SPECIF'

LEGEND

- 4.P1 100 DENOTES 100 THICK WALL PANEL TYPE
- 4.P1 150 DENOTES 150 THICK WALL PANEL TYPE
- 4.CP1 200 DENOTES 200 THICK LIFT/STAIR CORE WALL PANEL TYPE
- 4.BP1 175 DENOTES 175 THICK BALCONY WALL PANEL TYPE
- CC DENOTES CORNER PANEL CONNECTION
REFER TO DETAILS
- SC DENOTES SUSPENDED WALL PANEL CONNECTION
REFER TO DETAILS
- SCC DENOTES SUSPENDED CORNER PANEL CONNECTION
REFER TO DETAILS

LEVEL 4 FLOOR WALL PANEL PLAN
1:100

AD	AS NOTED	DG	FK	08.02.19
AC	AS NOTED	DG	FK	20.12.18
AB	AS NOTED	DG	FK	13.12.18
AA	FOR CONSTRUCTION	DG	FK	19.10.18
No	REVISION	DRAWN	CHE'KD	DATE

PROJECT
THE WILLCOX APARTMENTS
AT: 117 PROSPECT ROAD
PROSPECT, SA 5082
FOR: CITIFY & BFC PTY LTD

DRAWING TITLE
CONCRETE WALL PLANS - LEVEL 4

Civil

Environmental

Mechanical

Fire

Lifts

Structural

Geotechnical

Electrical

Hydraulics

Green ESD

Level 6, 100 Pirie Street,
Adelaide SA 5000
Telephone 08 8238 4100
Facsimile 08 8410 1405

TMK

CONCRETE SOLUTIONS

SCALES	AS SHOWN	COPYRIGHT RESERVED
DRAWN	DG	DRAWING No.
DATE	APRIL 2018	1802052-S304/AD
ENGINEER	FK	
CHECKED		

