

Smoke alarm Installation Compliance

Company Name:	<input type="text" value="Bert Farina Constructions"/>	Date:	<input type="text" value="31/3/2019"/>	Ref No:	<input type="text" value="3"/>
Site Name:	<input type="text" value="bert f-24 : 19c Gameau Road Paradise"/>	Permit to work requirement:	Yes <input type="checkbox"/>	No <input type="checkbox"/>	
Contractor:	<input type="text" value="Sparrow Electrical and Construction Services"/>	Approved By:	<input type="text" value="Jake Sparrow"/>		
Job/Task:	<input type="text" value="19c Gameau Road Paradise"/>	Asset:	<input type="text"/>		

Visually inspect alarms for condition (e.g dust/paint) Pass ☒ Fail ☐

Smoke alarm locations single storey Pass ☐ Fail ☐ N/A ☒

Smoke alarm locations multi-storey Pass ☒ Fail ☐ N/A ☐

Inspect alarms to ensure that a battery is properly installed Pass ☒ Fail ☐

Check that the power indicator light has illuminated Pass ☒ Fail ☐

Test the smoke alarm by pressing the test button to sound the alarm or engage the alarm test function in accordance with manufacturers instructions
Pass ☒ Fail ☐

Interconnected alarms operate Pass ☒ Fail ☐ N/A ☐

Where other warning devices are used as alarm indicating devices (eg lights or vibrating pads) check all devices to ensure that they are in place.
Pass ☒ Fail ☐ N/A ☐

Smoke Alarms Compliant Yes ☒

Alarms installed in suitable locations :

No ☐ N/A ☒

Alarms installed in suitable locations :

Yes ☒ No ☐ N/A ☐

