

# TENDER ADDENDUM

**Project:** 97 King William St, Kent Town

**Addendum No:** E02

**Issued To:** Anthony Donato Architects

**Ref No:** B8014

**Copied To:** \_\_\_\_\_

**Date:** 21/11/18

**Title:** Tender Addendum E02

**Sheet:** 1 of 2

Refer to following for changes to tender documentation:

Drawing E01\_rev A (Basement Plan):

- Stobie pole with SAPN service fuse shown.
- P7 electrical pit deleted.
- SAPN service fuse enclosure deleted.
- 15A SSO for HWS added.
- 15A SSO for CP added.

Drawing E01\_rev A (Ground Floor Plan):

- SAPN service fuse enclosure deleted.
- FCU-G-01 isolator deleted.
- Switchboard renamed as DB-GF-1
- ACC-G-01 isolator added.
- 10A SSO for TEF-01 added.

Drawing E02\_rev A (1<sup>st</sup> Floor Plan):

- HWU isolator deleted.
- 15A SSO for BWU added.
- Switchboards renamed as DB1-1, DB1-2 and DB1-3.
- Amp rating added to isolators.

Drawing E02\_rev A (2<sup>nd</sup> & 3rd Floor Plan):

- HWU isolator deleted.
- 15A SSO for BWU added.
- Switchboards renamed as DB2-1, DB2-2, DB2-3, DB3-1, DB3-2 and DB3-3.
- Amp rating added to isolators.
- Note 3 added.

Drawing E03\_rev A (Roof Plan):

- Note 3 amended.

Drawing E08\_rev A (Legend):

- Designations added.

Drawing E09\_rev A (Single Line Diagram):

- Changes as clouded



.....  
**Robert Bartosik**  
Electrical Services Engineer