


1. TYPE 'SL3' LIGHTS TO SWITCH ON DURING THE DAY (PE-CELL CONTROL) WHEN MOTION DETECTED. LOW BAY LIGHTS ARE NOT TO OPERATE AT NIGHT.
2. WHEN LIGHTING OCCUPANCY SENSOR DETECTS MOTION IN CAR PARK, ALL LIGHTS IN CAR PARK ARE TO SWITCH ON EXCEPT TYPE 'SL3' LIGHTS AT NIGHT.
3. FIP TO CONTROL FIRE PUMP (ON/OFF).



# BASEMENT PLAN

SCALE 1:100



	DRAWN	CLB	CHECKED	NC
	ENG	RB	Q.A.	AD
	DATE	MAR '18		SCALE 1:100 @ A1
			SHEET	4 OF 10
DRAWING No.				
<h1>B8014-E04</h1>				
PLOT DATE: 21/11/2018		Size	Rev.	
		A1	A	