

ELECTRICAL CERTIFICATE OF COMPLIANCE

As required by the Electricity Act 1996

Certificate Number: **E407081**

Owner/Client name	Bert Farina Constructions		
Installation Address	104/2 POST PARADE, ST CLAIR, SA 5011		
Premises Type	Flat/Unit		
Date of Electrical Work	Started: 03/01/2018	Finished: 24/04/2019	Submitted: 01/05/2019
Network Operator	SAPN		

SECTION A - JOB DETAILS

Work Category	Work Type	Work Performed
New Install	Other	Electrical Work Details: Installation of new apartment electrical, sub-board containing: 1 x 80A Main switch, 1 x 25A RBCO for A/C, 1 x 16A RCBO for Oven, 2 x 16A RCBO's for power, 1 x 10A RCBO for lights. Installation of all associated cabling, fittings and fixtures. (Outdoor A/C unit terminated by others, all plug in exhaust fans installed by others). Test and commission.

SECTION B - WARNING : Owners & operators of electrical installations must take reasonable steps to ensure that the electrical installation is safe. Maximum penalty \$250,000. Listed below are any items considered to be unsafe or requiring remedy.

Risk Assessment	None Observed
-----------------	---------------

REGISTERED ELECTRICAL WORKER: I certify the work detailed in this eCoC complies with and has been inspected and tested by me as required by the *Electricity Act 1996*.

Name	Samuel Smith
Licence Number	PGE260138
Date Certified	30/04/2019

CONTRACTOR/AUTHORISED PERSON: I certify that I am the contractor/duly authorised agent of the contractor and have or had a supervisory role in relation to the worker above and I am satisfied that the standards and requirements of the *Electricity Act 1996* have been complied with.

Also where applicable, I am satisfied that the auxiliary gas fitting and/or water plumbing work detailed above meets the requirements of the *Gas Act 1997* and Regulations and/or *Water Industry Act 2012* including Regulations and Standards.

Name	Matthew O'Neill		
Business Name	ODE Installations		
Licence Number	PGE172370		
Phone/Mobile	0401350679	Email	matthew@odeinstallations.com
Address	102 BAKER STREET, GLENGOWRIE, SA 5044		
Date Certified	01/05/2019		

The Technical Regulator does not endorse the contents of this electronic Certificate of Compliance (eCoC). The Technical Regulator does not accept responsibility for the truth or accuracy of the contents of this eCoC and will not be held liable for any loss or damage suffered in consequence of reliance upon the contents of this eCoC.

ELECTRICAL CERTIFICATE OF COMPLIANCE

As required by the *Electricity Act 1996*

Certificate Number: **E407081**

Information for Owners and Operators of Electrical Installations

(From the *Electricity Act 1996*)

Section 60 of the *Electricity Act 1996*

60—Responsibility of owner or operator of infrastructure or installation

(1b) A person who owns or operates an electrical installation must take reasonable steps to ensure that—

- (a) the installation complies with, and is operated in accordance with, technical and safety requirements imposed under the regulations; and
- (b) the installation is safe and safely operated.

Maximum penalty:

- (a) if the offender is a body corporate—a penalty of \$50 000;
- (b) in any other case—a penalty of \$10 000.

Expiation fee: \$315.

(2) For the purpose of ensuring under this section that an electrical installation complies with the technical and safety requirements and is safe, a person may, subject to the regulations, rely on a certificate of compliance issued under this Part in relation to the installation.

Section 61 of the *Electricity Act 1996*

61—Electrical installation work

(1) A person to whom this subsection applies who carries out work on an electrical installation or proposed electrical installation must ensure that—

- (a) the work is carried out as required under the regulations; and
- (b) examinations and tests are carried out as required under the regulations; and
- (c) the requirements of the regulations as to notification and certificates of compliance are complied with.

Maximum penalty:

- (a) if the offender is a body corporate—a penalty of \$50 000;
- (b) in any other case—a penalty of \$10 000.

Expiation fee: \$315.