





FIRE LEGEND	
SYMBOL	DESCRIPTION
	EXISTING FIRE PIPEWORK (REMAINS)
	NEW FIRE PIPEWORK (100 or 150 as noted)
	NEW FIRE PIPEWORK (>100 as noted)
	SPRINKLER CONTROL VALVE
	FIRE HYDRANT (EXTERNAL).
	FIRE HYDRANT (INTERNAL).
	FIRE HOSE REEL.
	FIRE BLANKET 2.0 SQM.
	D - DENOTES AB(E) DRY CHEMICAL 4.5kg CAPACITY FIRE EXTINGUISHER C - DENOTES CO2 (CARBON DIOXIDE) 3.5kg CAPACITY FIRE EXTINGUISHER H - DENOTES H2O (WATER) FIRE EXTINGUISHER 9.1L CAPACITY W - DENOTES WET CHEMICAL FIRE EXTINGUISHER 9.1L CAPACITY
	SPRINKLER HEAD, EXPOSED PENDANT (NO CEILING).
	CONCEALED SPACE SPRINKLER DRENCHER IN UPPER ROOF SPACE LEVEL.
	SPRINKLER HEAD, CONCEALED (RECESSED) CEILING MOUNTED. POWDERCOAT TO ARCHITECTS SELECTION.
	SPRINKLER HEAD, SIDE WALL.
	SPRINKLER HEAD, WALL WETTING.
	FIRE INDICATOR PANEL.
	ADDRESSABLE SMOKE DETECTOR.
	ADDRESSABLE SMOKE DETECTOR W SOUNDER BASE.
	COMBINED STROBE / SOUNDER
	PIPE RISER.
	50 RISER SIZE B RISER TYPE
	FS-FIRE SERVICE FR-FIRE HOSE REEL
	A-AGAINST WALL B-BUILT/CHASED IN WALL C-BUILT IN CAVITY D-IN DUCT E-BOXED IN BY BUILDER
U/G	UNDER GROUND
U/S	UNDER SLAB
O/C	OVER CEILING
SERVICE MATERIAL	
GS	GALVANISED STEEL
PW/C16	PIPE PRESSURE PIPE CLASS 16

B	UPDATED BUILDING CERTIFICATION ISSUE	CG	GJC	22.10.19
A	BUILDING APPROVAL ISSUE	CG	GJC	10.10.19
No	REVISION	DRAWN	CHE'KD	DATE

PROJECT
**PROPOSED MIXED
USE DEVELOPMENT**
AT: 76-78 COMMERCIAL ROAD
PORT ADELAIDE, SA
FOR: VITO GROUP PTY LTD.

DRAWING TITLE
FIRE SERVICES - FLOOR PLANS

Civil
Environmental
Mechanical
Fire
Lifts

Structural
Geotechnical
Electrical
Hydraulics
Green ESD

Level 6, 100 Pirie Street,
Adelaide SA 5000
Telephone 08 8238 4100
Facsimile 08 8410 1405
Berri Office: 25 Vaughan Terrace,
Berri SA 5343

SCALES		COPYRIGHT RESERVED
AS SHOWN		
DRAWN	CG	DRAWING No. 1907135-F2/B
DATE	SEP' 19	
ENGINEER	GJC	
CHECKED		

