


PUMP SHALL BE DUAL PUMP. THE PUMP CONTROLS SHALL BE SET UP TO ENABLE ALTERNATE PUMP OPERATION AT EACH START. IN THE EVENT THAT A PUMP FAILS TO OPERATE WHEN THE WATER LEVEL IN THE WELL REACHES THE PUMP START, THE OTHER PUMP SHALL BE ACTIVATED AND A VISIBLE ALARM INITIATED. IN THE EVENT THAT BOTH PUMPS FAIL TO OPERATE, AN AUDIBLE ALARM SHALL BE INITIATED. PROVIDE BACK-UP POWER SUPPLY IN CASE OF POWER FAILURE.

ALL LEVELS SHALL BE CONFIRMED ON SITE PRIOR TO CONSTRUCTION. SHOULD ANY DISCREPANCY OCCUR THE CONTRACTOR SHALL CONTACT THIS OFFICE IMMEDIATELY FOR FURTHER INSTRUCTION.

THE CONTRACTOR IS RESPONSIBLE FOR CHECKING LOCATION OF ALL UNDERGROUND SERVICES PRIOR TO COMMENCING ANY EXCAVATION WORK. ANY DAMAGE CAUSED TO ANY SERVICES SHALL BE REPORTED IMMEDIATELY TO THE SUPERINTENDANT & SHALL BE REPAIRED BY THE APPROPRIATE AUTHORITIES. ALL COSTS ASSOCIATED WITH REPAIRS SHALL BE AT THE CONTRACTOR'S EXPENSE. PHONE 'DIAL BEFORE YOU DIG' (1100) FOR ASSISTANCE.

Client CITIFY & BFC PTY LTD	N 
Drawing Title BASEMENT LEVELS & DRAINAGE LAYOUT	Scale 1:100
Drawing Number 20492-C01	Issue 02

FOR CONSTRUCTION