

1. [REMOVED]
2. BALCONY OUTLETS AND EXHAUST FANS WITHIN APARTMENTS TO BE SUPPLIED FROM LOCAL APARTMENT LOAD CENTRE. FAN TO BE SWITCHED FROM 2ND POLE OF LOCAL LIGHT SWITCH. TYPICAL.
3. REFER TO ARCHITECTURAL DOCUMENTATION FOR FULL REQUIREMENTS OF ELECTRICAL INSTALLATION WITHIN APARTMENTS. PROVIDE ALL REQUIRED MATERIALS AND FIXTURES AND INSTALL ACCORDING TO ARCHITECT SET-OUT (TYPICAL).



PROVIDE P23 COMMUNICATIONS CONDUITS IN CEILING FOR RETICULATION OF OPTICOMM FIBRE CABLING. COORDINATE FINAL ROUTES ON SITE WITH OPTICOMM FOR WORKSHOP DRAWINGS (TYPICAL).

B	CONSTRUCTION ISSUE	24.03.20	MS
A	CONSTRUCTION ISSUE	14.02.20	MS
REV\N	DESCRIPTION	DATE	CHK'D

© Copyright Lucid Consulting Australia 24/03/2020 2:51:33 PM

FOR CONSTRUCTION



CITIFY 

GEMMA | LEA  
www.gemma.com.au  
gemma@gemma.com.au  
DESIGN STUDIOS


**LUCID**  
CONSULTING AUSTRALIA

Level 3/169, Pirie St Adelaide SA 5000  
Phone: (08) 8407 9700  
Email: [adelaide@lucidconsulting.com.au](mailto:adelaide@lucidconsulting.com.au)

PROJECT  
HYDE PARK PLACE  
248 UNLEY ROAD, HYDE PARK  
ELECTRICAL SERVICES

---

DRAWING  
4TH FLOOR POWER, COMMUNICATIONS AND  
SECURITY ARRANGEMENT



NOT FOR CONSTRUCTION PURPOSES UNLESS STAMPED FOR  
CONSTRUCTION. VERIFY DIMENSIONS AND LEVELS ON SITE  
BEFORE SETTING OUT. DO NOT SCALE. REFER TO FIGURED  
DIMENSIONS - IN mm UNLESS OTHERWISE STATED.

Scale	Design: MD	No. in Set	Date
1 : 100	Drawn: PY	10 of 24	FEB 2020
	Review: PAC		

Orig. Size Drawing no. Revision

A1 LCE14462-E205 B