

LIGHTING MOTION SENSORS IN AMENITIES TO BE COMPLETE WITH 10 MINUTES RUN ON TIMER. PROVIDE RELAYS AND CONTACTORS TO CONTROL TOILET EXHAUST FAN (TYPICAL).

HIGHBAY LIGHT FITTINGS TO BE CONNECTED TO PE-CELL AND TIMECLOCK, TO OPERATE ONLY DURING DAYLIGHT HOURS.

CANOPY LIGHTING TO BE CONNECTED TO PE-CELL AND TIMECLOCK FOR AFTER HOURS LIGHTING CONTROL (TYPICAL).

FOYER FEATURE PENDANT. SELECTION TO BE CONFIRMED BY ARCHITECT.

ISOLATOR FOR ILLUMINATED FOYER SIGNAGE AT HIGH LEVEL.

DB.C L

DB.C L

DB.C L

DB.C L

DB.C L

TG.02B L

TG.03A L

LC-TG.01


LC-T.CAFE

LC-TG.02A

LC-TG.02B

LC-TG.03A

FOR CONSTRUCTION



REV	DESCRIPTION	DATE	CHKD
B	CONSTRUCTION ISSUE	24.03.20	MS
A	CONSTRUCTION ISSUE	14.02.20	MS


© Copyright Lucid Consulting Australia 24/03/2020 2:51:53 PM

CITIFY bfc

GEMMA LEA DESIGN STUDIO

LUCID CONSULTING AUSTRALIA
Level 3/169, Pirie St Adelaide SA 5000
Phone: (08) 8407 9700
Email: adelaide@lucidconsulting.com.au

PROJECT
HYDE PARK PLACE
248 UNLEY ROAD, HYDE PARK
ELECTRICAL SERVICES
DRAWING
GROUND FLOOR LUMINAIRE ARRANGEMENT



NOT FOR CONSTRUCTION PURPOSES UNLESS STAMPED FOR CONSTRUCTION. VERIFY DIMENSIONS AND LEVELS ON SITE BEFORE SETTING OUT. DO NOT SCALE. REFER TO FIGURED DIMENSIONS - IN mm UNLESS OTHERWISE STATED.

Scale	Design: MD	No. in Set	Date
1 : 100	Drawn: PY	14 of 24	FEB 2020
Orig. Size	Drawing no.	Revision	
A1	LCE14462-E209	B	