



FESTOON LIGHTING TO COMMUNAL PLAZA ACROSS VOID. PROVIDE PE CELL AND TIME CLOCK CONTROL.


ALL EXIT AND EMERGENCY LIGHTING THROUGHOUT COMMON AREA TO BE LOCAL LIGHTING CIRCUITS VIA EMERGENCY TEST SWITCH AND UNSWITCHED ACTIVE.

COMMON AREA LIGHTING TO BE REVISED BY CONTRACTOR. PROPOSED ARRANGEMENT CONSISTING OF DOWNLIGHTS AND PE-CELL CONTROL TO COMPLY WITH NCC-2016 REQUIREMENTS. ARRANGEMENT TO BE SUBMITTED TO ENGINEER FOR REVIEW AND APPROVAL, INCLUDING GENERAL LAYOUT, CIRCUITING AND CONTROLS, AND PHOTOMETRIC PLOT.

REV	DESCRIPTION	DATE	CHKD
B	CONSTRUCTION ISSUE	24.03.20	MS
A	CONSTRUCTION ISSUE	14.02.20	MS


© Copyright Lucid Consulting Australia 24/03/2020 2:52:04 PM

FOR CONSTRUCTION



LUCID
CONSULTING AUSTRALIA
Level 3/169, Pirie St Adelaide SA 5000
Phone: (08) 8407 9700
Email: adelaide@lucidconsulting.com.au

PROJECT
HYDE PARK PLACE
248 UNLEY ROAD, HYDE PARK
ELECTRICAL SERVICES
DRAWING
2ND FLOOR LUMINAIRE ARRANGEMENT



NOT FOR CONSTRUCTION PURPOSES UNLESS STAMPED FOR CONSTRUCTION. VERIFY DIMENSIONS AND LEVELS ON SITE BEFORE SETTING OUT. DO NOT SCALE. REFER TO FIGURED DIMENSIONS - IN mm UNLESS OTHERWISE STATED.

Scale	Design: MD	No. in Set	Date
1 : 100	Drawn: PY	16 of 24	FEB 2020
Orig. Size	Drawing no.	Revision	
A1	LCE14462-E211	B	