


ALL EXIT AND EMERGENCY LIGHTING
THROUGHOUT COMMON AREA TO BE LOCAL
LIGHTING CIRCUITS VIA EMERGENCY TEST
SWITCH AND UNSWITCHED ACTIVE.

COMMON AREA LIGHTING TO BE REVISED BY
CONTRACTOR. PROPOSED ARRANGEMENT
CONSISTING OF DOWNLIGHTS AND PE-CELL
CONTROL TO COMPLY WITH NCC-2016
REQUIREMENTS. ARRANGEMENT TO BE
SUBMITTED TO ENGINEER FOR REVIEW AND
APPROVAL, INCLUDING GENERAL LAYOUT,
CIRCUITING AND CONTROLS, AND
PHOTOMETRIC PLOT.

| | | | |
|-----|--------------------|----------|------|
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| B | CONSTRUCTION ISSUE | 24.03.20 | MS |
| A | CONSTRUCTION ISSUE | 14.02.20 | MS |
| REV | DESCRIPTION | DATE | CHKD |

FOR CONSTRUCTION




LUCID

CONSULTING AUSTRALIA

Level 3/169, Pirie St Adelaide SA 5000
Phone: (08) 8407 9700
Email: adelaide@lucidconsulting.com.au

PROJECT
HYDE PARK PLACE
248 UNLEY ROAD, HYDE PARK
ELECTRICAL SERVICES
DRAWING
3RD FLOOR LUMINAIRE ARRANGEMENT



NOT FOR CONSTRUCTION PURPOSES UNLESS STAMPED FOR
CONSTRUCTION. VERIFY DIMENSIONS AND LEVELS ON SITE
BEFORE SETTING OUT. DO NOT SCALE. REFER TO FIGURED
DIMENSIONS - IN mm UNLESS OTHERWISE STATED.

| | | | |
|---------|-------------|------------|----------|
| Scale | Design: MD | No. in Set | Date |
| 1 : 100 | Drawn: PY | 17 of 24 | FEB 2020 |
| | Review: PAC | | |

| | | |
|------------|---------------|----------|
| Orig. Size | Drawing no. | Revision |
| A1 | LCE14462-E212 | B |