


ALL EXIT AND EMERGENCY LIGHTING  
THROUGHOUT COMMON AREA TO BE LOCAL  
LIGHTING CIRCUITS VIA EMERGENCY TEST  
SWITCH AND UNSWITCHED ACTIVE.

COMMON AREA LIGHTING TO BE REVISED BY  
CONTRACTOR. PROPOSED ARRANGEMENT  
CONSISTING OF DOWNLIGHTS AND PE-CELL  
CONTROL TO COMPLY WITH NCC-2016  
REQUIREMENTS. ARRANGEMENT TO BE  
SUBMITTED TO ENGINEER FOR REVIEW AND  
APPROVAL, INCLUDING GENERAL LAYOUT,  
CIRCUITING AND CONTROLS, AND  
PHOTOMETRIC PLOT.

B	CONSTRUCTION ISSUE	24.03.20	MS	
A	CONSTRUCTION ISSUE	14.02.20	MS	
REV	DESCRIPTION	DATE	CHKD	


© Copyright Lucid Consulting Australia 24/03/2020 2:52:26 PM

FOR CONSTRUCTION



**LUCID**  
CONSULTING AUSTRALIA  
Level 3/169, Pirie St Adelaide SA 5000  
Phone: (08) 8407 9700  
Email: adelaide@lucidconsulting.com.au

PROJECT  
HYDE PARK PLACE  
248 UNLEY ROAD, HYDE PARK  
ELECTRICAL SERVICES  
DRAWING  
5TH FLOOR LUMINAIRE ARRANGEMENT



NOT FOR CONSTRUCTION PURPOSES UNLESS STAMPED FOR  
CONSTRUCTION. VERIFY DIMENSIONS AND LEVELS ON SITE  
BEFORE SETTING OUT. DO NOT SCALE. REFER TO FIGURED  
DIMENSIONS - IN mm UNLESS OTHERWISE STATED.

Scale	Design: MD	No. in Set	Date
1 : 100	Drawn: PY	19 of 24	FEB 2020
	Review: PAC		

Orig. Size	Drawing no.	Revision
A1	LCE14462-E214	B