

**PUMP NOTES:**

PUMP SHALL BE DUAL PUMP. THE PUMP CONTROLS SHALL BE SET UP TO ENABLE ALTERNATE PUMP OPERATION AT EACH START. IN THE EVENT THAT A PUMP FAILS TO OPERATE WHEN THE WATER LEVEL IN THE WELL REACHES THE PUMP START, THE OTHER PUMP SHALL BE ACTIVATED AND A VISIBLE ALARM INITIATED. IN THE EVENT THAT BOTH PUMPS FAIL TO OPERATE, AN AUDIBLE ALARM SHALL BE INITIATED. PROVIDE BACK-UP POWER SUPPLY IN CASE OF POWER FAILURE.

NOTE:

REFER TO ARCHITECTS DRAWINGS FOR ALL SETOUT DIMENSIONS. ALL LEVELS SHALL BE CONFIRMED ON SITE PRIOR TO CONSTRUCTION. SHOULD ANY DISCREPANCY OCCUR THE CONTRACTOR SHALL CONTACT THIS OFFICE IMMEDIATELY FOR FURTHER INSTRUCTION.

CONTRACTORS NOTES:

COVER LEVELS GIVEN FOR PITS ARE NOMINAL ONLY. COVER LEVELS SHALL MATCH FINISHED PAVING LEVELS.

THE CONTRACTOR IS RESPONSIBLE FOR CHECKING LOCATION OF ALL UNDERGROUND SERVICES PRIOR TO COMMENCING ANY EXCAVATION WORK. ANY DAMAGE CAUSED TO ANY SERVICES SHALL BE REPORTED IMMEDIATELY TO THE SUPERINTENDANT & SHALL BE REPAIRED BY THE APPROPRIATE AUTHORITIES. ALL COSTS ASSOCIATED WITH REPAIRS SHALL BE AT THE CONTRACTOR'S EXPENSE. PHONE 'DIAL BEFORE YOU DIG' (1100) FOR ASSISTANCE.

FOR TENDER

02.07.2019	ISSUED FOR TENDER	T
28.03.2019	ISSUED FOR APPROVAL	D
12.03.2019	PRELIMINARY ISSUE	C
01.03.2019	PRELIMINARY ISSUE	B
06.02.2019	ISSUED FOR INFORMATION	A
Date	Revision	Issue

PT Design

PT Design Pty Ltd 141-149 Ifould Street Adelaide SA 5000
T (08 9412 4300) E [ptdesign@ptdesign.net.au]

Designed	SR	Drawn	SR
Approved		Date	JAN '19
CIVIL		Sheet	1 of 3

Project
**PROPOSED DEVELOPMENT
248 UNLEY ROAD
HYDE PARK SA**

Client
CITIFY & BFC PTY LTD

Drawing Title
**BASEMENT LEVELS &
DRAINAGE LAYOUT**

Drawing Number
20492-C01

Name: 20492-C01.dwg

Date: 2.7.2019

Time: 15:20:23

© Copyright

0 2500 5000 10000
SCALE 1:100 @B1