

NOTES:

1. DOOR ACCESS CONTROL WITHIN STAIRWELL TO BE CONFIGURED AS 'FAIL-SAFE', WITH ELECTRIC STRIKE TO RELEASE ON FIRE ALARM SIGNAL.
2. BALCONY OUTLETS AND EXHAUST FANS WITHIN APARTMENTS TO BE SUPPLIED FROM LOCAL APARTMENT LOAD CENTRE. FAN TO BE SWITCHED FROM 2ND POLE OF LOCAL LIGHT SWITCH. TYPICAL.
3. REFER TO ARCHITECTURAL DOCUMENTATION FOR FULL REQUIREMENTS OF ELECTRICAL INSTALLATION WITHIN APARTMENTS. PROVIDE ALL REQUIRED MATERIALS AND FIXTURES AND INSTALL ACCORDING TO ARCHITECT SET-OUT (TYPICAL).

FINAL POOL PLANT ROOM EQUIPMENT LAYOUT TO BE CONFIRMED BY POOL CONTRACTOR. ALLOW TO COORDINATE ON SITE WITH OTHER SERVICES AND EQUIPMENT.

OPTICAL NETWORK TERMINATION (ONT)

PROVIDE 2 OFF DUAL POWER OUTLETS FOR ONT.
(TYPICAL PER APARTMENT)

APARTMENT LOAD CENTRE (LC-A1.01)

(TYPICAL PER APARTMENT)

POOL DISTRIBUTION BOARD (DB.POOL)

ELECTRICAL AND COMMUNICATIONS


RISER CUPBOARD

- CONTAINS:
- BUILDING OPTICOMM DISTRIBUTION
 - ELECTRICAL METER PANELS
 - SECURITY/MATV/INTERCOM EQUIPMENT

PROVIDE P23 COMMUNICATIONS CONDUITS IN CEILING FOR RETICULATION OF OPTICOMM FIBRE CABLING. COORDINATE FINAL ROUTES ON SITE WITH OPTICOMM FOR WORKSHOP DRAWINGS (TYPICAL).


TENANCY LOAD CENTRE (LC-TG.03B)

LEVEL 1.
SIZE, QUANTITY AND LOCATION TO BE CONFIRMED.



T1	TENDER ISSUE	23.05.19	MS
REV N	DESCRIPTION	DATE	CHK'D


TENDER ISSUE



GEMMA LEA
DESIGN STUDIO

LUCID
CONSULTING AUSTRALIA
Level 3/169, Pirie St Adelaide SA 5000
Phone: (08) 8407 9700
Email: adelaide@lucidconsulting.com.au

PROJECT
HYDE PARK PLACE
248 UNLEY ROAD, HYDE PARK
ELECTRICAL SERVICES
DRAWING
1ST FLOOR POWER, COMMUNICATIONS AND
SECURITY ARRANGEMENT



NOT FOR CONSTRUCTION PURPOSES UNLESS STAMPED FOR CONSTRUCTION. VERIFY DIMENSIONS AND LEVELS ON SITE BEFORE SETTING OUT. DO NOT SCALE. REFER TO FIGURED DIMENSIONS - IN mm UNLESS OTHERWISE STATED.

Scale	Design: MD	No. in Set	Date
1 : 100	Drawn: PY	7 of 24	MAY 2019
Orig. Size	Drawing no.	Revision	
A1	LCE14462-E202	T1	