


1. DOOR ACCESS CONTROL WITHIN STAIRWELL TO BE CONFIGURED AS "FAIL-SAFE"; WITH ELECTRIC STRIKE TO RELEASE ON FIRE ALARM SIGNAL.
2. BALCONY OUTLETS AND EXHAUST FANS WITHIN APARTMENTS TO BE SUPPLIED FROM LOCAL APARTMENT LOAD CENTER. FAN TO BE SWITCHED FROM 2ND POLE OF LOCAL LIGHT SWITCH. TYPICAL.
3. REFER TO ARCHITECTURAL DOCUMENTATION FOR FULL REQUIREMENTS OF ELECTRICAL INSTALLATION WITHIN APARTMENTS. PROVIDE ALL REQUIRED MATERIALS AND FIXTURES AND INSTALL ACCORDING TO ARCHITECT SET-OUT (TYPICAL).



TENDER ISSUE




© Copyright Lucid Consulting Australia 23/05/2019 12:21:38 PM



GEMMA | LEA
DESIGN STUDIO

LUCID
CONSULTING AUSTRALIA

Level 3/169, Pirie St Adelaide SA 5000
Phone: (08) 8407 9700
Email: adelaide@lucidconsulting.com.au



NOT FOR CONSTRUCTION PURPOSES UNLESS STAMPED FOR
CONSTRUCTION. VERIFY DIMENSIONS AND LEVELS ON SITE
BEFORE SETTING OUT. DO NOT SCALE. REFER TO FIGURED
DIMENSIONS - IN mm UNLESS OTHERWISE STATED.

Scale	Design: MD	No. in Set	Date
1 : 100	Drawn: PY	10 of 24	MAY 2019
	Review: PAC		

Orig. Size	Drawing no.	Revision
A1	LCE14462-E205	T1