APPROXIMATE LOCATION OF SITE FIRE INDICATOR PANEL AND EMERGENCY CONTROL PANEL.

TOWNHOUSE FIRE SERVICES DESIGN:-
• ALLOW FOR DEDICATED 50W AMPLIFIER AND OCCUPANT WARNING CIRCUIT FOR THE TOWNHOUSES IN THE SITE FIP.
• ALLOW FOR MINIMUM 2 EMERGENCY EVACUATION SPEAKERS WITHIN EACH TOWNHOUSE.
• SPEAKERS ACTIVATE UPON CARPARK SPRINKLER ALARM.

REFER TO FIRE ENGINEERING REPORT FOR FINAL FIRE SERVICES REQUIREMENTS WITHIN TOWNHOUSES.

SITE SAMFS BRIGADE BOOSTER ASSEMBLY CONSISTING OF:
• 150Ø QUAD FEED HYDRANT
• 150Ø QUAD BOOSTER (COMBINED FIRE HYDRANT AND SPRINKLER SYSTEM)
REFER TO DRAWING LCE14462-F300 FOR DETAIL.

PROVIDE EXTERNAL STROBE TO INDICATE PUMP RUN.

PROVIDE NEW DOUBLE HEADED EXTERNAL ATTACK HYDRANT. PROVIDE WEATHERPROOF SIGNAGE ADJACENT STATING 'ATTACK HYDRANT CONNECTED TO PUMPED AND BOOSTED BUILDING SUPPLY' OR SIMILAR, IN ACCORDANCE WITH THE REQUIREMENTS OF THE FIRE ENGINEERING REPORT.

REFER TO DRAWING LCE14462-F200 FOR CONTINUATION.

CONTRACTOR TO MAKE APPLICATION AND PAY ASSOCIATED FEES TO 'SA WATER CORPORATION FOR THE PROVISION OF A NEW Ø150 FIRE CONNECTION.

INSTALL EXTERNAL 'FIRE' STROBE ON THE BUILDING FACADE FACING UNLEY ROAD. FIRE SERVICES CONTRACTOR TO PROVIDE ALL ASSOCIATED CABLING AND COMPLETE FINAL CONNECTION TO FDCIE. COORDINATE FINAL LOCATION OF STROBE WITH ARCHITECT.

REV'N	DESCRIPTION	DATE	CHK'D
T1	TENDER ISSUE	23.05.19	MM

TENDER ISSUE

2 1 0 1 2 4 6 8 10 m
SCALEBAR 1:200

TO BE PRINTED IN COLOUR
THE PURPOSE OF THIS DOCUMENT IS INTENDED TO BE VIEWED OR PRINTED IN COLOUR FOR THE FULL EXTENT OF THE SCOPE OF WORKS TO BE SHOWN.

CITIFY bfc GEMMA | LEA DESIGN STUDIO

LUCID CONSULTING AUSTRALIA
Level 3/169, Pirie St Adelaide SA 5000
Phone: (08) 8407 9700
Email: adelaide@lucidconsulting.com.au

PROJECT
HYDE PARK PLACE
248 UNLEY ROAD, HYDE PARK
FIRE SERVICES

DRAWING
SITE PLAN

NOT FOR CONSTRUCTION PURPOSES UNLESS STAMPED FOR CONSTRUCTION. VERIFY DIMENSIONS AND LEVELS ON SITE BEFORE SETTING OUT. DO NOT SCALE. REFER TO FIGURED DIMENSIONS - IN mm UNLESS OTHERWISE STATED.

Scale	Design: LM/AR	No. in Set	Date
1 : 200	Drawn: SHA Review: MM	3 of 14	MAY 2019
Orig. Size	Drawing no.		Revision
A1	LCE14462-F100		T1

© Copyright Lucid Consulting Australia 5/23/2019 12:47:08 PM