




HATCHED AREA INDICATES POD BATHROOM FOR APARTMENTS. POD TO BE CONSTRUCTED OFF SITE BY BUILDER COMPLETE WITH FIXTURES, TAPWARE AND INTERNAL ABOVE SLAB DRAINAGE PIPEWORK. POD CONSTRUCTION SHALL INCLUDE RISERS EXTENDING TO BELOW AND CAPPED OFF BELOW SLAB FOR TOILET, HAND BASIN AND SHOWER. CONTRACTOR SHALL CONNECT TO RISERS AND EXTEND AS SHOWN IN ACCORDANCE WITH AS/NZS3500. REFER TO DETAIL ON DRAWING NUMBER 'LCE14462-H302' FOR FURTHER INFORMATION. (TYPICAL).

PROVIDE Ø40 TRAPPED WASTE TO HAND BASIN INWALL AND EXTEND Ø75 WASTE TO VENTED DRAIN IN ACCORDANCE WITH AS/NZS3500. HAND BASIN SHALL BE SUPPLIED WITH INTERNAL OVERFLOW (TYPICAL).






PROVIDE "REHAU RAUPIANO" FLOOR WASTE GULLY TO SHOWER STRIP DRAIN AND EXTEND Ø75 WASTE TO VENTED DRAIN AS SHOWN. SHOWER STRIP DRAIN MUST HAVE MINIMUM Ø100 OUTLET (TYPICAL).



PROVIDE Ø50 TRAPPED WASTE TO LAUNDRY TROUGH AND EXTEND TO ADJACENT FLOOR WASTE GULLY AS SHOWN. PROVIDE SPIGOT ABOVE TRAP FOR CONNECTION TO WASHING MACHINE PUMPED DISCHARGE. REFER TO DETAIL ON DRAWING NUMBER 'LCE14462-H302' FOR FURTHER INFORMATION (TYPICAL).



PROVIDE Ø50 BRANCH VENT TO BRANCH DRAIN IN ACCORDANCE WITH AS/NZS3500 AND CONNECT TO RELIEF VENT ABOVE SLAB LEVEL OF FLOOR ABOVE (TYPICAL).



PROVIDE Ø100 INSPECTION OPENING TO SURFACE COMPLETE WITH NON-SLIP CHROME PLATED COVER. REFER TO DETAIL ON DRAWING NUMBER 'LCE14462-H302' FOR FURTHER INFORMATION (TYPICAL).

PROVIDE 80x40 PVC CONE TUNDISH AT HIGH LEVEL IN LAUNDRY CUPBOARD BENEATH LAUNDRY TROUGH FOR RECEIPT OF MECHANICAL SERVICES CONDENSATE COMPLETE WITH AIR GAP AND EXTEND Ø40 WASTE TO ADJACENT FLOOR WASTE GULLY. COORDINATE FINAL LOCATION OF TUNDISH ON SITE WITH MECHANICAL SERVICES TRADE (TYPICAL).





PROVIDE Ø50 TRAPPED WASTE TO KITCHEN SINK AND EXTEND Ø75 WASTE TO VENTED DRAIN AS SHOWN IN ACCORDANCE WITH AS/NZS3500. PROVIDE SPIGOT ABOVE TRAP FOR FUTURE CONNECTION TO DISHWASHER PUMPED WASTE. REFER TO DETAIL ON DRAWING NUMBER 'LCE14462-H302' FOR FURTHER INFORMATION (TYPICAL).

PROVIDE Ø50 AIR ADMITTANCE VALVE AT HIGH LEVEL IN KITCHEN JOINERY BENEATH SINK IN ACCORDANCE WITH AS/NZS3500 AND MANUFACTURERS INSTALLATION INSTRUCTIONS. CONNECT Ø50 VENT PIPEWORK TO SINK RISER (TYPICAL).

NOTE:
ALL SEWER AND TRADE WASTE PIPEWORK SHALL BE INSTALLED AT THE FOLLOWING MINIMUM GRADES UNLESS OTHERWISE STATED:

- Ø40-Ø75: 2.50% MINIMUM
- Ø110: 1.65% MINIMUM
- Ø160: 1.00% MINIMUM


ALL VENT PIPEWORK SHALL BE INSTALLED AT 1.25% MINIMUM GRADE UNLESS OTHERWISE STATED.



T1	TENDER ISSUE	23.05.19	KR
REV N	DESCRIPTION	DATE	CHKD

© Copyright Lucid Consulting Australia 23/05/2019 11:55:38 AM

TENDER ISSUE




TO BE PRINTED IN COLOUR
THE PURPOSE OF THIS DOCUMENT IS INTENDED TO BE VIEWED OR PRINTED IN COLOUR FOR THE FULL EXTENT OF THE SCOPE OF WORKS TO BE SHOWN.



PROJECT
HYDE PARK PLACE
248 UNLEY ROAD, HYDE PARK
HYDRAULIC SERVICES

DRAWING
4TH FLOOR SANITARY DRAINAGE ARRANGEMENT



NOT FOR CONSTRUCTION PURPOSES UNLESS STAMPED FOR CONSTRUCTION. VERIFY DIMENSIONS AND LEVELS ON SITE BEFORE SETTING OUT. DO NOT SCALE. REFER TO FIGURED DIMENSIONS - IN mm UNLESS OTHERWISE STATED.

Scale	Design: JZ	No. in Set	Date
1 : 100	Drawn: JZ	10 of 25	MAY 2019
Review: KR			

Orig. Size	Drawing no.	Revision
A1	LCE14462-H205	T1