

APT 6.04

APT 6.01

APT 6.02

APT 6.03

Ø65 RELIEF VENT AND Ø65 STACK VENT SHALL COMBINE ABOVE SLAB LEVEL AND EXTEND TO ABOVE ROOF AS Ø65 VENT IN ACCORDANCE WITH AS/NZS3500 (TYPICAL).

PROVIDE Ø50 WASTE COMPLETE WITH SCREWED CAP OFF Ø65 SINK WASTE RISER FOR FUTURE CONNECTION TO SPA DRAIN (TYPICAL).

PROVIDE Ø40 TRAPPED WASTE TO HAND BASIN INWALL AND EXTEND Ø75 WASTE TO VENTED DRAIN IN ACCORDANCE WITH AS/NZS3500. HAND BASIN SHALL BE SUPPLIED WITH INTERNAL OVERFLOW (TYPICAL).

PROVIDE "REHAU RAUPIANO" FLOOR WASTE GULLY TO SHOWER STRIP DRAIN AND EXTEND Ø75 WASTE TO VENTED DRAIN AS SHOWN. SHOWER STRIP DRAIN MUST HAVE MINIMUM 4-3300 QUALITY TYPICAL.


— PROVIDE Ø50 TRAPPED W. BATH, AND EXTEND Ø75 V. AS SHOWN IN ACCORDANCE

— PROVIDE Ø50 TRAPPED W. WASTE TO VENTED DRAIN AS/NZS3500. PROVIDE SPI TO DISHWASHER PUMPED NUMBER 'LCE14462-H302'

— PROVIDE Ø100 INSPECTION NON-SLIP CHROME PLATE NUMBER 'LCE14462-H302'

— PROVIDE Ø50 TRAPPED W. ADJACENT FLOOR WASTE CONNECTION TO WASHING ON DRAWING NUMBER 'L'

TENDER ISSUE




THE PURPOSE OF THIS DOCUMENT IS INTENDED TO
BE VIEWED OR PRINTED IN COLOUR FOR THE FULL
EXTENT OF THE SCOPE OF WORKS TO BE SHOWN.



GEMMA | LEA
DESIGN STUDIO

PROJECT
HYDE PARK PLACE
248 UNLEY ROAD, HYDE PARK
HYDRAULIC SERVICES

DRAWING
6TH FLOOR SANITARY DRAINAGE ARRANGEMENT



NOT FOR CONSTRUCTION PURPOSES UNLESS STAMPED FOR
CONSTRUCTION. VERIFY DIMENSIONS AND LEVELS ON SITE
BEFORE SETTING OUT. DO NOT SCALE. REFER TO FIGURED
DIMENSIONS - IN mm UNLESS OTHERWISE STATED.

Scale	Design: JZ	No. in Set	Date
1 : 100	Drawn: JZ	12 of 25	MAY 2019

Orig. Size	Drawing no.	Revision
A1	LCE14462-H207	T1