



REFER DRAWING S00 FOR GENERAL NOTES

CONCRETE BEAM SCHEDULE			
MARK	WIDTH X DEPTH	REINF.	LIGS.
G.EB1	550 x 600	REFER TO ELEVATION	
G.EB2	1100 x 600	REFER TO ELEVATION	
G.EB3	550 x 600	REFER TO ELEVATION	
G.EB4	550 x 600	REFER TO ELEVATION	
G.EB5	550 x 600	REFER TO ELEVATION	
G.EB6	550 x 600	REFER TO ELEVATION	
G.EB7	600 x 400	REFER TO ELEVATION	
G.CB1	1200/560 x 600	REFER TO ELEVATION	
G.CB2	1200 x 600	REFER TO ELEVATION	
G.CB3	1200 x 600	REFER TO ELEVATION	
G.CB4	1200 x 600	REFER TO ELEVATION	
G.CB5	2000 x 800 / 1200 x 600	REFER TO ELEVATION	
G.CB6	1200 x 600	REFER TO ELEVATION	
G.CB7	1500 x 800 / 1200/775 x 600	REFER TO ELEVATION	
G.CB8	1200 x 600	REFER TO ELEVATION	
G.CB9	1200 x 600	4-N20 (2T,2B)	N12 @ 300 C/C
G.CB10	1200 x 600	4-N20 (2T,2B)	N12 @ 300 C/C
G.CB11	1200 x 600	REFER TO ELEVATION	
G.CB12	400 x 600	4-N20 (2T,2B)	N12 @ 300 C/C
G.CB13	1200 x 600	REFER TO ELEVATION	
G.CB14	400 x 600	4-N20 (2T,2B)	N12 @ 300 C/C
G.CB15	500 x 1090	4-N20 (2T,2B)	N12 @ 300 C/C
G.CB16	2800 x 800	REFER TO ELEVATION	
G.CB17	1200 x 600	REFER TO ELEVATION	
G.CB18	400 x 600	4-N20 (2T,2B)	N12 @ 300 C/C
G.CB19	500 x 550	4-N20 (2T,2B)	N10 @ 300 C/C

GROUND FLOOR MARKING PLAN

1:100

REFER TO DRAWINGS S311 & S312 FOR CAPPING BEAM RL'S

CONCRETE COLUMN SCHEDULE			
MARK	WIDTH X LENGTH	REINF.	LIGS.
B.CC1	350 x 700	12-N28 VERTICAL	2/W10 LIGS + 1/W10 LINK REFER TO COLUMN ELEVATION

DECKING MEMBER SCHEDULE		
MARK	MEMBER	REMARKS
PF1	700 SQ x 700 DEEP	MASS CONCRETE PAD
SC	75 x 75 x 5.0 SHS	10 BASE PL, 4-M16 ANCHORS 10 CAP/CLEAT PL, 4-M16 BOLTS TO DB1
DB1	2/240 x 45 F17 (SEASONED)	DECK BEARER
WP1	140 x 45 F17 (SEASONED)	WALL PLATE - M12 ANCHORS @ 450 C/C INTO GEB1
DJ1	2/140 x 35 F17 (SEASONED)	DECK JOIST @ 450 C/C

STEELWORK SCHEDULE		
MARK	MEMBER	REMARKS
SS1	180 PFC	STAIR STRINGER - REFER TO DETAIL
G.F1	180 PFC	LANDING BEAM - SITE WELD TO CAST-IN PLATE

STEELWORK NOTES:

- ALL STEELWORK TO BE GRADE 300+
- ALL STEEL HOLLOW SECTION MEMBERS TO BE GRADE C450+ UNO.
- ALL BOLTS TO BE GRADE 8.8/S. UNO
- ALL ANCHORS TO BE HILTI HY200 INSTALLED IN ACCORDANCE WITH MANUFACTURERS SPECIFICATIONS.
- ALL EXPOSED STEELWORK TO HAVE A PROTECTIVE BARRIER THAT IS ADEQUATE FOR THE RELEVANT EXPOSURE CONDITIONS.
- PROVIDE WELDED SLEEVES TO ALL HOLLOW SECTION MEMBERS AT BOLTING LOCATIONS.
- ALL SECONDARY FRAMING, TRIMMERS, CLADDING SUPPORT MEMBERS AND CLEATS TO BE PROVIDE AS REQUIRED IN ACCORDANCE WITH THE CLADDING MANUFACTURERS AND THE ARCHITECTURAL SPECIFICATIONS.

AB	AS NOTED	DG	FK	13.12.18
AA	FOR CONSTRUCTION	DG	FK	19.10.18

No	REVISION	DRAWN	CHE'KD	DATE
----	----------	-------	--------	------

PROJECT
THE WILLCOX APARTMENTS
AT: 117 PROSPECT ROAD
PROSPECT, SA 5082
FOR: CITIFY & BFC PTY LTD

DRAWING TITLE
GROUND FLOOR MARKING PLAN

Civil

Environmental

Mechanical

Fire

Lifts

Structural

Geotechnical

Electrical

Hydraulics

Green ESD

Level 6, 100 Pirie Street,
Adelaide SA 5000
Telephone 08 8238 4100
Facsimile 08 8410 1405

**TMC**
CONCRETE THE BUSINESS

SCALES		COPYRIGHT RESERVED
AS SHOWN		
DRAWN	DG	DRAWING No. 1802052-S102/AB
DATE	APRIL 2018	
ENGINEER	FK	
CHECKED		